

## WISCONSIN DEPARTMENT OF SAFETY AND PROFESSIONAL SERVICES



### **Wisconsin Department of Safety and Professional Services Access to the Public Records of the Reports of Decisions**

This Reports of Decisions document was retrieved from the Wisconsin Department of Safety and Professional Services website. These records are open to public view under Wisconsin's Open Records law, sections 19.31-19.39 Wisconsin Statutes.

#### **Please read this agreement prior to viewing the Decision:**

- The Reports of Decisions is designed to contain copies of all orders issued by credentialing authorities within the Department of Safety and Professional Services from November, 1998 to the present. In addition, many but not all orders for the time period between 1977 and November, 1998 are posted. Not all orders issued by a credentialing authority constitute a formal disciplinary action.
- Reports of Decisions contains information as it exists at a specific point in time in the Department of Safety and Professional Services data base. Because this data base changes constantly, the Department is not responsible for subsequent entries that update, correct or delete data. The Department is not responsible for notifying prior requesters of updates, modifications, corrections or deletions. All users have the responsibility to determine whether information obtained from this site is still accurate, current and complete.
- There may be discrepancies between the online copies and the original document. Original documents should be consulted as the definitive representation of the order's content. Copies of original orders may be obtained by mailing requests to the Department of Safety and Professional Services, PO Box 8935, Madison, WI 53708-8935. The Department charges copying fees. *All requests must cite the case number, the date of the order, and respondent's name* as it appears on the order.
- Reported decisions may have an appeal pending, and discipline may be stayed during the appeal. Information about the current status of a credential issued by the Department of Safety and Professional Services is shown on the Department's Web Site under "License Lookup."

The status of an appeal may be found on court access websites at:

<http://ccap.courts.state.wi.us/InternetCourtAccess> and <http://www.courts.state.wi.us/wscca>

- Records not open to public inspection by statute are not contained on this website.

**By viewing this document, you have read the above and agree to the use of the Reports of Decisions subject to the above terms, and that you understand the limitations of this on-line database.**

**Correcting information on the DSPS website:** An individual who believes that information on the website is inaccurate may contact [DSPS@wisconsin.gov](mailto:DSPS@wisconsin.gov)



**Tony Evers, Governor**  
**Dawn Crim, Secretary**

## NOTICE OF VIOLATIONS AND ORDERS

February 26, 2018

**CUST ID No.: 1470722**      **TRANSACTION No.: 3200231**  
**Phone: 262-277-1078**

**TINA SCHRADER-BERTE**  
**12919 WEST GREENFIELD AVE**  
**NEW BERLIN WI 53151**

**Site ID No.: 855976** 4483 Chain O Lakes Road  
**SITE ADDRESS:** 4483 Chain O Lakes Road  
Vilas County, Town of Lincoln  
**Site Contact:** Tina Schrader-Berte  
**Contact Phone:** (262)277-1078  
**Contact E-mail:** [tina@proedcontinuum.com](mailto:tina@proedcontinuum.com)

### Regulated Objects:

Nature of Complaint Summary: Electrical violations  
Object Type: Complaint    Regulated Object ID No.: 1809708 (17 UNL 162)  
Last Inspection Date: November 6 2017

**0006076**

### INVESTIGATION NOTES:

This DEPARTMENT ORDER is issued as a result of an inspection on the above referenced site.

The following violations were revealed:


- 1) The branch circuits that were installed to supply the receptacles in the guest bedroom closet do not have GFCI protection. 2011 National Electrical Code (NEC) § 210.12(A)
- 2) The nonmetallic cable installed above the suspended ceiling in the basement is not installed through bored holes or on running boards. 2011 NEC § 334.15(A)
- 3) The dimmer switches in the kitchen are controlling loads in excess of the rating of the switches. Wis. Admin. Code § SPS 316.110
- 4) The branch circuits that were installed to supply the receptacles in the bunkbeds in the basement do not have AFCI protection. 2011 NEC § 210.12(A)
- 5) The garage receptacles, that were added, do not have GFCI protection. 2011 NEC § 210.8(A)(2)
- 6) The receptacle boxes in the living room are not flush with the finished combustible wall surface. 2011 NEC § 314.20.
- 7) The washer in the basement is in the required working space of the electrical panel. 2011 NEC § 110.26(A)(1)
- 8) Equipment grounding conductors and grounded conductors are terminated in the same terminal. 2011 NEC § 408.41
- 9) The conductors that leave the panel in the basement and extend outside of the house are not installed using a Chapter 3 wiring method. 2011 NEC § 300.3(A)
- 10) The new countertop by the kitchen range does not have receptacle outlets installed to meet the spacing requirements. 2011 NEC § 210.52(C)(1)

You are hereby ordered to have the installation corrected to conform to the indicated provisions of the Wisconsin Administrative Code and/or Wisconsin Statutes. This installation shall be corrected by the compliance date noted, and upon correction of violations I must be notified. If you fail to comply, this order is enforceable in circuit court pursuant to Wis. Stat. § 101.02(13), Stats., with forfeitures ranging from \$10 to \$100 per day for each violation

If you have any questions regarding this matter, please feel free to contact me at the number listed below.

**Wis. Admin. Code § SPS 303.03** Permits any person affected by a rule of the department to petition for a variance of the rule. The petition needs to establish equivalency to the rule, be provided on the form from the department and be submitted with accompanying fee and municipal recommendation.

**Wis. Stat. § 101.02(6)** Any employer or other person interested either because of ownership in or occupation of any property affected by any such order, or otherwise, may petition for a hearing on the reasonableness of any order of the department in the manner provided in this subchapter. All requests must be received within 30 days of the date of this Order and shall set out specifically and in full detail the order upon which a hearing is desired and every reason why such order is unreasonable, and every issue to be considered by the department on the hearing. The petitioner shall be deemed to have finally waived all objections to any irregularities and illegalities in the order upon which a hearing is sought other than those set forth in the petition.

ATTORNEY NAME: Matthew McCasland	INVESTIGATION DATE: 11/7/2017
PHONE/WORK HOURS: (608)266-9814 ,	
E-MAIL: matthew.mccasland@wisconsin.gov	INVESTIGATION TYPE: Requested
SIGNATURE:  DATE: 2/26/19	INVESTIGATION SOURCE: Other
	COMPLIANCE DATE: 04/8/19
	Fee Required: (Invoice will be send Separately)
	PTO Expires:

cc: Craig Mulder, Electrical Engineer, (608) 444-5701