

WISCONSIN DEPARTMENT OF SAFETY AND PROFESSIONAL SERVICES



Wisconsin Department of Safety and Professional Services Access to the Public Records of the Reports of Decisions

This Reports of Decisions document was retrieved from the Wisconsin Department of Safety and Professional Services website. These records are open to public view under Wisconsin's Open Records law, sections 19.31-19.39 Wisconsin Statutes.

Please read this agreement prior to viewing the Decision:

- The Reports of Decisions is designed to contain copies of all orders issued by credentialing authorities within the Department of Safety and Professional Services from November, 1998 to the present. In addition, many but not all orders for the time period between 1977 and November, 1998 are posted. Not all orders issued by a credentialing authority constitute a formal disciplinary action.
- Reports of Decisions contains information as it exists at a specific point in time in the Department of Safety and Professional Services data base. Because this data base changes constantly, the Department is not responsible for subsequent entries that update, correct or delete data. The Department is not responsible for notifying prior requesters of updates, modifications, corrections or deletions. All users have the responsibility to determine whether information obtained from this site is still accurate, current and complete.
- There may be discrepancies between the online copies and the original document. Original documents should be consulted as the definitive representation of the order's content. Copies of original orders may be obtained by mailing requests to the Department of Safety and Professional Services, PO Box 8935, Madison, WI 53708-8935. The Department charges copying fees. *All requests must cite the case number, the date of the order, and respondent's name* as it appears on the order.
- Reported decisions may have an appeal pending, and discipline may be stayed during the appeal. Information about the current status of a credential issued by the Department of Safety and Professional Services is shown on the Department's Web Site under "License Lookup."

The status of an appeal may be found on court access websites at:

<http://ccap.courts.state.wi.us/InternetCourtAccess> and <http://www.courts.state.wi.us/wscca>

- Records not open to public inspection by statute are not contained on this website.

By viewing this document, you have read the above and agree to the use of the Reports of Decisions subject to the above terms, and that you understand the limitations of this on-line database.

Correcting information on the DSPS website: An individual who believes that information on the website is inaccurate may contact DSPS@wisconsin.gov



Tony Evers, Governor
Dawn B. Crim, Secretary

NOTICE OF VIOLATIONS AND ORDERS

June 24, 2019

CUST ID No.: 1482883 TRANSACTION No.: 3264035
Phone: 262-745-6948

Site ID No.: 858716 Deanna Palombo Home
SITE ADDRESS: W1035 Violet Road
Walworth County, Village of Bloomfield
Site Contact: Deanna Painter
Contact Phone: 262-745-6948

DEANNA PALOMBO
W1035 VIOLET RD
GENOA CITY WI 53128

ORDER 0006258

Regulated Objects:

Nature of Complaint Summary: DECK NOT BUILT TO CODE
Object Type: Complaint Regulated Object ID No.: 1829678 (18 COM 205)
Last Inspection Date: April 11, 2019

INVESTIGATION NOTES:

This DEPARTMENT ORDER is issued as a result of an inspection on the above referenced site.

The following violations were revealed:

Wis. Admin. Code § SPS 321.225(2) referenced Prescriptive Deck Code SPS 320 - 325 Appendix B

Wis. Admin. Code § SPS 321.04(2)(e) Tread and Riser Uniformity. Stair treads contained variations beyond the maximum allowed 3/8-inch dimension.

Wis. Admin. Code § SPS 321.04(2)(f) Open Risers. Stair risers contained open space larger than the maximum allowable 4-inch dimension.

UDC Appendix B, Section 2, Footings, and Post Connections. Post not placed within the center 1/3 of the footing.

UDC Appendix B, Section 3, Post to Beam Connections. Beam connections to post not in compliance with this section of the Appendix B prescriptive deck code. See Figure 2, Section 3.

UDC Appendix B, Section 14, Stairs. Stair stringer is not attached/bearing properly to the deck landing as required by this section. See Figure 28, Section 14.

UDC Appendix B, Section 14, Stairs. Lower end of stair stringer not attached properly to posts as required by this section. See Figure 29, Section 14.


You are hereby ordered to have the installation corrected to conform to the indicated provisions of the Wisconsin Administrative Code and/or Wisconsin Statutes. This installation shall be corrected by the compliance date noted, and upon correction of violations I must be notified. If you fail to comply, this order is enforceable in circuit court pursuant to Wis. Stat. § 101.02(13), Stats., with forfeitures ranging from \$10 to \$100 per day for each violation.

If you have any questions regarding this matter, please feel free to contact me at the number listed below.

Wis. Admin. Code § SPS 303.03 Permits any person affected by a rule of the department to petition for a variance of the rule. The petition needs to establish equivalency to the rule, be provided on the form from the department and be submitted with accompanying fee and municipal recommendation.

ORDER 000852

Wis. Stat. § 101.02(6) Any employer or other person interested either because of ownership in or occupation of any property affected by any such order, or otherwise, may petition for a hearing on the reasonableness of any order of the department in the manner provided in this subchapter. All requests must be received within 30 days of the date of this Order and shall set out specifically and in full detail the order upon which a hearing is desired and every reason why such order is unreasonable, and every issue to be considered by the department on the hearing. The petitioner shall be deemed to have finally waived all objections to any irregularities and illegalities in the order upon which a hearing is sought other than those set forth in the petition.

ATTORNEY NAME: Matthew McCasland	INVESTIGATION DATE: 04/11/2019
PHONE/WORK HOURS: (608)266-9814	
E-MAIL: matthew.mccasland@wisconsin.gov	INVESTIGATION TYPE: Requested
SIGNATURE: 	INVESTIGATION SOURCE: Other
DATE: 6/24/19	COMPLIANCE DATE: 07/26/19
	Fee Required: (Invoice will be sent separately)
	PTO Expires:

cc: Robert Kanter, Udc Engineering Consultant, (608) 261-6541,