

WISCONSIN DEPARTMENT OF SAFETY AND PROFESSIONAL SERVICES



Wisconsin Department of Safety and Professional Services Access to the Public Records of the Reports of Decisions

This Reports of Decisions document was retrieved from the Wisconsin Department of Safety and Professional Services website. These records are open to public view under Wisconsin's Open Records law, sections 19.31-19.39 Wisconsin Statutes.

Please read this agreement prior to viewing the Decision:

- The Reports of Decisions is designed to contain copies of all orders issued by credentialing authorities within the Department of Safety and Professional Services from November, 1998 to the present. In addition, many but not all orders for the time period between 1977 and November, 1998 are posted. Not all orders issued by a credentialing authority constitute a formal disciplinary action.
- Reports of Decisions contains information as it exists at a specific point in time in the Department of Safety and Professional Services data base. Because this data base changes constantly, the Department is not responsible for subsequent entries that update, correct or delete data. The Department is not responsible for notifying prior requesters of updates, modifications, corrections or deletions. All users have the responsibility to determine whether information obtained from this site is still accurate, current and complete.
- There may be discrepancies between the online copies and the original document. Original documents should be consulted as the definitive representation of the order's content. Copies of original orders may be obtained by mailing requests to the Department of Safety and Professional Services, PO Box 8935, Madison, WI 53708-8935. The Department charges copying fees. *All requests must cite the case number, the date of the order, and respondent's name* as it appears on the order.
- Reported decisions may have an appeal pending, and discipline may be stayed during the appeal. Information about the current status of a credential issued by the Department of Safety and Professional Services is shown on the Department's Web Site under "License Lookup."

The status of an appeal may be found on court access websites at:

<http://ccap.courts.state.wi.us/InternetCourtAccess> and <http://www.courts.state.wi.us/wscca>

- Records not open to public inspection by statute are not contained on this website.

By viewing this document, you have read the above and agree to the use of the Reports of Decisions subject to the above terms, and that you understand the limitations of this on-line database.

Correcting information on the DSPS website: An individual who believes that information on the website is inaccurate may contact DSPS@wisconsin.gov



Tony Evers, Governor
Dawn B. Crim, Secretary

NOTICE OF VIOLATIONS AND ORDERS

September 17, 2019

CUST ID No.: 1284360 TRANSACTION No.: 3273861
Phone: 715.856.5531

JOE SCHLIES
PO BOX 373
WAUSAUKEE WI 54177

Site ID No.: 800743 Wausaukee Bowl
SITE ADDRESS: 326 Main St
Marinette County, Village of Wausaukee
Site Contact: Joseph Schlies
Contact Phone: 715.856.5531

ORDER 0006433

Regulated Objects:

Nature of Complaint Summary: BUILDING LACKS PROPER GREASE INTERCEPTOR
Object Type: Complaint Regulated Object ID No.: 1835044 (18 COM 152)
Last Inspection Date: July 24, 2019

INVESTIGATION NOTES:

This DEPARTMENT ORDER is issued as a result of an inspection on the above referenced site, Wausaukee Bowl.

The following violations were revealed:

Violation: Lack of grease interceptor installed.

Wis. Admin. Code § SPS 382.34(3): Any deleterious waste material which is discharged into a plumbing system shall be directed to a wastewater treatment or holding device. The wastewater treatment or holding device shall be capable of separating, diluting or neutralizing the deleterious waste material to a degree that the wastewater is no longer deleterious. Wastewater treatment or holding devices that retain any waste materials shall be designed and installed to facilitate periodic removal or treatment, or both.

Wis. Admin. Code § SPS. 382.34(5): All plumbing installations for occupancies, other than dwelling units, where grease, fats, oils or similar waste products of cooking or food are introduced into the drain system shall be provided with grease and oil treatment in accordance with this subsection.

Suggested Action: Install grease interceptor. Ensure proper design and sizing is completed for the grease interceptor by a licensed plumber/plumbing designer. The grease interceptor will require to be submitted to the department for plan review. Review the full plumbing code for specific installation requirements.


You are hereby ordered to have the installation corrected to conform to the indicated provisions of the Wisconsin Administrative Code and/or Wisconsin Statutes. This installation shall be corrected by the compliance date noted, and upon correction of violations I must be notified. If you fail to comply, this order is enforceable in circuit court pursuant to Wis. Stat. § 101.02(13), Stats., with forfeitures ranging from \$10 to \$100 per day for each violation

If you have any questions regarding this matter, please feel free to contact me or Ron Soquet at the numbers listed below.

Wis. Admin. Code § SPS 303.03 Permits any person affected by a rule of the department to petition for a variance of the rule. The petition needs to establish equivalency to the rule, be provided on the form from the department and be submitted with accompanying fee and municipal recommendation.

Wis. Stat. § 101.02(6) Any employer or other person interested either because of ownership in or occupation of any property affected by any such order, or otherwise, may petition for a hearing on the reasonableness of any order of the department in the manner provided in this subchapter. All requests must be received within 30 days of the date of this Order and shall set out specifically and in full detail the order upon which a hearing is desired and every reason why such order is unreasonable, and every issue to be considered by the department on the hearing. The petitioner shall be deemed to have finally waived all

objections to any irregularities and illegalities in the order upon which a hearing is sought other than those set forth in the petition.

ATTORNEY NAME: Matthew McCasland		INVESTIGATION DATE: 7/24/2019
PHONE/: (608)266-9814		
E-MAIL: matthew.mccasland@wisconsin.gov		INVESTIGATION TYPE: Requested
SIGNATURE:	DATE:	INVESTIGATION SOURCE: Other
	9/17/19	COMPLIANCE DATE: 12/29/19

cc: Ron Soquet, Plumbing Plan Reviewer, (920) 492-6502.