

WISCONSIN DEPARTMENT OF SAFETY AND PROFESSIONAL SERVICES



Wisconsin Department of Safety and Professional Services Access to the Public Records of the Reports of Decisions

This Reports of Decisions document was retrieved from the Wisconsin Department of Safety and Professional Services website. These records are open to public view under Wisconsin's Open Records law, sections 19.31-19.39 Wisconsin Statutes.

Please read this agreement prior to viewing the Decision:

- The Reports of Decisions is designed to contain copies of all orders issued by credentialing authorities within the Department of Safety and Professional Services from November, 1998 to the present. In addition, many but not all orders for the time period between 1977 and November, 1998 are posted. Not all orders issued by a credentialing authority constitute a formal disciplinary action.
- Reports of Decisions contains information as it exists at a specific point in time in the Department of Safety and Professional Services data base. Because this data base changes constantly, the Department is not responsible for subsequent entries that update, correct or delete data. The Department is not responsible for notifying prior requesters of updates, modifications, corrections or deletions. All users have the responsibility to determine whether information obtained from this site is still accurate, current and complete.
- There may be discrepancies between the online copies and the original document. Original documents should be consulted as the definitive representation of the order's content. Copies of original orders may be obtained by mailing requests to the Department of Safety and Professional Services, PO Box 8935, Madison, WI 53708-8935. The Department charges copying fees. *All requests must cite the case number, the date of the order, and respondent's name* as it appears on the order.
- Reported decisions may have an appeal pending, and discipline may be stayed during the appeal. Information about the current status of a credential issued by the Department of Safety and Professional Services is shown on the Department's Web Site under "License Lookup."

The status of an appeal may be found on court access websites at:

<http://ccap.courts.state.wi.us/InternetCourtAccess> and <http://www.courts.state.wi.us/wscga>

- Records not open to public inspection by statute are not contained on this website.

By viewing this document, you have read the above and agree to the use of the Reports of Decisions subject to the above terms, and that you understand the limitations of this on-line database.

Correcting information on the DSPS website: An individual who believes that information on the website is inaccurate may contact DSPS@wisconsin.gov



Tony Evers, Governor
Dawn B. Crim, Secretary

NOTICE OF VIOLATIONS AND ORDERS

October 22, 2019

CUST ID No.: 1492821 TRANSACTION No.: 3282555
Phone: 608-429-9988

SOPHIE HUANG
YUMMY CHINESE RESTAURANT
140 N MAIN STREET
PARDEEVILLE WI 53954

Site ID No.: 790217 Yummy Chinese Restaurant - Pardeeville
SITE ADDRESS: 140 N Main Street
Columbia County, Village of Pardeeville
Site Contact: Sophie Huang
Contact Phone: 608-429-9988

ORDER 0006516

Regulated Objects:

Nature of Complaint Summary: PLUMBING VIOLATIONS
Object Type: Complaint Regulated Object ID No.: 1838021 (19 COM 113)
Last Inspection Date: September 10, 2019

INVESTIGATION NOTES:

This DEPARTMENT ORDER is issued as a result of an inspection on the above referenced site. Please consult Wisconsin statutes and the administrative code for complete language.

The following violations were revealed:

1. Violation: Kitchen bathroom lavatory is not vented.

Wis. Admin. Code § SPS 382.31(3)a Vents. Every trap and trapped plumbing fixture shall be provided with an individual vent, except as otherwise permitted in this chapter. Vents and venting systems shall be designed and installed so that the water seal of a trap shall be subject to a maximum pneumatic pressure differential equal to one inch of water column.

2. Violation: No vent witnessed on the grease interceptor.

Wis. Admin. Code § SPS 382.31(3)a Vents. Every trap and trapped plumbing fixture shall be provided with an individual vent, except as otherwise permitted in this chapter. Vents and venting systems shall be designed and installed so that the water seal of a trap shall be subject to a maximum pneumatic pressure differential equal to one inch of water column.

3. Violation: The pre-wash and wash compartments bypass the grease interceptor.

Wis. Admin. Code § SPS 382.34(5)(b)1c-d. 'Public sewers.' All new, altered or remodeled plumbing systems which discharge to public sewers shall be provided with one or more grease interceptors.

c. The wash compartment of a scullery sink shall discharge through a grease interceptor.

d. The pre-wash compartment not discharging through a garbage disposal shall discharge through a grease interceptor.

4. Violation: The existing grease interceptor is not properly sized due to incorrect calculations regarding the number of compartments discharging into it.

Wis. Admin. Code § SPS 382.34(5)(d)1. 'Flow rating.' An interior grease interceptor shall be capable of accommodating a flow of at least 15 gallons per minute, but not less than the manufacturer's specifications.

5. Violation: The condensate tube is discharging into the kitchen bathroom toilet tank.

Wis. Admin. Code § SPS 382.33(8)(d) Other receptors. A plumbing fixture may not be used as a receptor for indirect or local waste piping, except as provided in subds. 1. to 7.

1. The indirect waste piping of a portable dishwasher or water treatment device serving one or 2 outlets may discharge into a kitchen sink of a dwelling unit or to a branch tail piece serving a kitchen sink.
2. The indirect waste piping of an automatic clothes washer or water treatment device may discharge into a laundry tray.
3. The indirect or local waste piping serving a cross connection control device or assembly, water treatment device, air conditioner, humidifier or furnace condensate may discharge into a branch tailpiece serving a laundry tray.
4. The local waste piping serving a water heater temperature and pressure relief valve, water treatment device, cross connection control device or assembly, humidifier, sterilizer, or a furnace or air conditioner may discharge into the riser of a floor drain when installed in accordance with sub. (7) (b).
5. The indirect or local waste piping serving a water heater temperature and pressure relief valve, water treatment device, cross connection control device or assembly, or a furnace or air conditioner may discharge to a floor served by a floor drain so as not to create a health or safety hazard.
6. The indirect or local waste piping serving a water heater temperature and pressure relief valve or water treatment device may discharge through the cover of a clear water sump so as not to adversely affect floats by means of a fixed air gap installed in accordance with subs. (7) (a) 2. and (8).
7. The indirect waste piping serving a dental mold grinder may discharge into the riser or a trap serving a laboratory sink that is provided with a plaster trap and is installed within 3 feet of the mold grinder.

6. Violation: The water supply is incorrect.

Wis. Admin. Code § SPS 382.40(7) Sizing of water supply piping. See code for full language.

7. Violation: Water hammer arrestors missing.

Wis. Admin. Code § SPS 382.40(8)(f) Water hammer arrestors. All plumbing fixtures, appliances and appurtenances with 3/8" or larger inlet openings and with solenoid actuated quick closing valves shall be provided with water hammer arrestors. Water hammer arrestors shall be installed in the fixture supplies serving the fixtures, appliances or appurtenances. Water hammer arrestors shall be accessible.

8. Violation: The water heater relief valve is not piped.

Wis. Admin. Code § SPS 382.40(5)(d)5. Every relief valve which is designed to discharge water or steam shall be connected to a discharge pipe.

9. Violation: 4-way splitter installed on the laundry tub faucet.

Wis. Admin. Code § SPS 382.41(3)(a-b) Water supply systems and the connection of each plumbing fixture, piece of equipment, appliance or nonpotable water piping system shall be designed, installed and maintained in such a manner to prevent the contamination of water supplies by means of cross connections.

10. Violation: Water supply materials for the 4-way splitter is not code compliant.

Wis. Admin. § SPS 384.30 When selecting the material and determining size for a plumbing system, due consideration shall be given to the waste that will discharge to the plumbing system and to the soil, liquid and atmospheric environments where the plumbing system will be located.

Wis. Admin. Code § SPS 384.40 Joints and connections


Suggested Actions for all violations: Hire licensed plumber to correct code violations.

You are hereby ordered to have the installation corrected to conform to the indicated provisions of the Wisconsin Administrative Code and/or Wisconsin Statutes. This installation shall be corrected by the compliance date noted, and upon correction of violations I must be notified. You may also directly contact Bo Hachtel at the number listed below. If you fail to comply, this order is enforceable in circuit court pursuant to Wis. Stat. § 145.12(4), Stats., with forfeitures ranging from \$10 to \$1000 per day for each violation.

If you have any questions regarding this matter, please feel free to contact me at the number listed below.

Wis. Admin. Code § SPS 303.03 Permits any person affected by a rule of the department to petition for a variance of the rule. The petition needs to establish equivalency to the rule, be provided on the form from the department and be submitted with accompanying fee and municipal recommendation.

Wis. Stat. § 101.02(6) Any employer or other person interested either because of ownership in or occupation of any property affected by any such order, or otherwise, may petition for a hearing on the reasonableness of any order of the department in the manner provided in this subchapter. All requests must be received within 30 days of the date of this Order and shall set out specifically and in full detail the order upon which a hearing is desired and every reason why such order is unreasonable, and every issue to be considered by the department on the hearing. The petitioner shall be deemed to have finally waived all objections to any irregularities and illegalities in the order upon which a hearing is sought other than those set forth in the petition.

ATTORNEY NAME: Matthew McCasland	INVESTIGATION DATE: 9/10/2019
PHONE: (608)266-9814	
E-MAIL: matthew.mccasland@wisconsin.gov	INVESTIGATION TYPE: Requested
SIGNATURE: 	INVESTIGATION SOURCE: Other
DATE: 10/22/17	COMPLIANCE DATE: 12/09/19

Cc: Bo Hachtel, Plumbing Plan Reviewer, (608) 266-2128