

## WISCONSIN DEPARTMENT OF SAFETY AND PROFESSIONAL SERVICES



### Wisconsin Department of Safety and Professional Services Access to the Public Records of the Reports of Decisions

This Reports of Decisions document was retrieved from the Wisconsin Department of Safety and Professional Services website. These records are open to public view under Wisconsin's Open Records law, sections 19.31-19.39 Wisconsin Statutes.

#### Please read this agreement prior to viewing the Decision:

- The Reports of Decisions is designed to contain copies of all orders issued by credentialing authorities within the Department of Safety and Professional Services from November, 1998 to the present. In addition, many but not all orders for the time period between 1977 and November, 1998 are posted. Not all orders issued by a credentialing authority constitute a formal disciplinary action.
- Reports of Decisions contains information as it exists at a specific point in time in the Department of Safety and Professional Services data base. Because this data base changes constantly, the Department is not responsible for subsequent entries that update, correct or delete data. The Department is not responsible for notifying prior requesters of updates, modifications, corrections or deletions. All users have the responsibility to determine whether information obtained from this site is still accurate, current and complete.
- There may be discrepancies between the online copies and the original document. Original documents should be consulted as the definitive representation of the order's content. Copies of original orders may be obtained by mailing requests to the Department of Safety and Professional Services, PO Box 8935, Madison, WI 53708-8935. The Department charges copying fees. *All requests must cite the case number, the date of the order, and respondent's name* as it appears on the order.
- Reported decisions may have an appeal pending, and discipline may be stayed during the appeal. Information about the current status of a credential issued by the Department of Safety and Professional Services is shown on the Department's Web Site under "License Lookup."

The status of an appeal may be found on court access websites at:

<http://ccap.courts.state.wi.us/InternetCourtAccess> and <http://www.courts.state.wi.us/wscga>

- Records not open to public inspection by statute are not contained on this website.

**By viewing this document, you have read the above and agree to the use of the Reports of Decisions subject to the above terms, and that you understand the limitations of this on-line database.**

**Correcting information on the DSPS website:** An individual who believes that information on the website is inaccurate may contact [DSPS@wisconsin.gov](mailto:DSPS@wisconsin.gov)



Tony Evers, Governor  
Dawn B. Crim, Secretary

## NOTICE OF VIOLATIONS AND ORDERS

November 15, 2019

CUST ID No.: 1058477      TRANSACTION No.: 3283681

Site ID No.: 726730 Yukon Trails RV & Camping Resort  
SITE ADDRESS: N2330 County Road HH  
Juneau County, Town of Kildare

MHC YUKON TRAILS LLC  
PO BOX 6115  
CHICAGO IL 60606-6115

**ORDER 0006549**

### Regulated Objects:

Nature of Complaint Summary: ELECTRICAL VIOLATIONS AT CAMPGROUND

Object Type: Complaint      Regulated Object ID No.: 1838638 (19 COM 116)

Last Inspection Date: September 27, 2019

**INVESTIGATION NOTES:** On September 27, 2019, DSPS Electrical Inspector Anthony Tadysak inspected the site and found electrical violations that require correcting.

This DEPARTMENT ORDER is issued as a result of an inspection on the above referenced site.

**Wis. Admin. Code § SPS 316.002 Scope.** (1) General. Except as provided in sub. (2), this chapter applies to electrical wiring installations.

**Wis. Admin. Code § SPS 316.007(1)(a) Adoption of standards by reference.** Primary Standards. The following standards are incorporated by reference into this chapter, subject to the modifications specified in this chapter: Except as provided under par. (am), National Fire Protection Association (NFPA), One Batterymarch Park, Quincy, MA 02169-7471, telephone 800-344-3555, www.nfpa.org: NFPA 70 National Electrical Code, (NEC) – 2017.

**Wis. Admin. Code § SPS 316.011(2)(a) Administration.** Department Administration. In municipalities not exercising jurisdiction under sub. (1), the department shall provide permit and inspection services for the installation of electrical wiring on farms and in public buildings, places of employment, campgrounds, manufactured home communities, public marinas, piers, docks, or wharves and recreational vehicle parks.

The following violations were revealed:

**1. Violation:** Electrical distribution panels and related wiring inside the pool pump house have been subjected to deteriorating agents.

**Wis. Admin. Code § SPS 316.021 Maintenance.** All electrical wiring installations and equipment shall be cleaned and inspected at intervals as experience has shown to be necessary. Any equipment or electrical wiring installation known to be defective so as to endanger life or property shall be promptly repaired, permanently disconnected or isolated until repairs can be made.

**Suggested Action:** Replace the electrical panels and all rusted & deteriorated electrical wiring in the pool pump house.

**2. Violation:** The front entrance sign has Type UF Cable installed which has been exposed and subjected to physical damage.

**2017 NEC § 340.12** UF Cable shall not be used where subjected to physical damage.

**Suggested Action:** Rework the electrical wiring at the front entrance sign location to an acceptable NEC Chapter 3 wiring method and protect the new wiring installed from physical damage.

**3. Violation:** Site No. 173 has Type UF Cable installed which has been exposed and subjected to physical damage.

**2017 NEC § 340.12** UF Cable shall not be used where subjected to physical damage.

**Suggested Action:** Rework the electrical wiring at Site No. 173 to an acceptable NEC Chapter 3 wiring method and protect the new wiring installed from physical damage.

**4. Violation:** Site No. 177 has electrical openings at the electrical distribution panel.

**2017 NEC § 110.12(A) Unused Openings.** Unused openings shall be closed.

**Suggested Action:** All electrical openings in the electrical distribution panel shall be closed.

**5. Violation:** Electrical distribution wiring at the exterior campground panels is exposed to physical damage and not properly terminated in the exterior electrical panels.

**Wis. Admin. Code § SPS 316.021 Maintenance.** All electrical wiring installations and equipment shall be cleaned and inspected at intervals as experience has shown to be necessary. Any equipment or electric wiring installation known to be defective so as to endanger life or property shall be promptly repaired, permanently disconnected or isolated until repairs can be made.

**Suggested Action:** Protect the exterior distribution wiring at the panel locations and rework the wiring fastening to the electrical panels. Exterior distribution wiring shall be installed in an approved sleeve/connector when it enters the electrical distribution.

**6. Violation:** Electrical distribution panels are being protected from the elements in deteriorated wood boxes and currently subjected to water entering the panels.

**Wis. Admin. Code § SPS 316.021 Maintenance.** All electrical wiring installations and equipment shall be cleaned and inspected at intervals as experience has shown to be necessary. Any equipment or electric wiring installation known to be defective so as to endanger life or property shall be promptly repaired, permanently disconnected or isolated until repairs can be made.

**Suggested Action:** Install additional protection for the wood boxes so that water cannot get into the exterior electrical distribution panels.

**7. Violation:** #12 AWG copper Underground Feeder wire has been installed at the front entrance sign location. The #12 AWG wiring is currently being protected by a 50-ampere breaker. The overcurrent ampacity of a #12 AWG copper wire shall not exceed 20-amperes.

**2017 NEC § 240.4 Protection of Conductors.** Conductors, other than flexible cords, flexible cables, and fixture wires, shall be protected against overcurrent in accordance with their ampacities specified.

**Suggested Action:** Rework the front entrance electrical distribution overcurrent device and distribution to no more than 20-Amperes.

**8. Violation:** Electrical openings exist at the electrical distribution panels throughout the campground.

**2017 NEC § 110.12(A) Unused Openings.** Unused openings shall be closed.

**Suggested Action:** All electrical openings in electrical distribution panels shall be closed.

**9. Violation:** All electrical circuits lack proper identification as to their clear, evident and specific purpose or use.

**2017 NEC § 408.4 Circuit directory required.**


**Suggested Action:** Provide circuit directories for all the electrical distribution panels in the campground.

You are hereby ordered to have the installation corrected to conform to the indicated provisions of the Wisconsin Administrative Code and/or Wisconsin Statutes. This installation shall be corrected by the compliance date noted, and upon correction of violations I must be notified. If you fail to comply, this order is enforceable in circuit court pursuant to Wis. Stat. Sec. 101.02(13), Stats., with forfeitures ranging from \$10 to \$100 per day for each violation.

If you have any questions regarding this matter, please feel free to contact me at the number listed below.

Wis. Admin. Code § SPS 303.03 Permits any person affected by a rule of the department to petition for a variance of the rule. The petition needs to establish equivalency to the rule, be provided on the form from the department and be submitted with accompanying fee and municipal recommendation.

Wis. Stat. § 101.02(6) Any employer or other person interested either because of ownership in or occupation of any property affected by any such order, or otherwise, may petition for a hearing on the reasonableness of any order of the department in the manner provided in this subchapter. All requests must be received within 30 days of the date of this Order and shall set out specifically and in full detail the order upon which a hearing is desired and every reason why such order is unreasonable, and every issue to be considered by the department on the hearing. The petitioner shall be deemed to have finally waived all objections to any irregularities and illegalities in the order upon which a hearing is sought other than those set forth in the petition.

ATTORNEY NAME: Matthew McCasland	INVESTIGATION DATE: 9/27/2019
PHONE/WORK HOURS: 608-266-9814	
E-MAIL: matthew.mccasland@wisconsin.gov	INVESTIGATION TYPE: Requested
SIGNATURE:  DATE: 11/15/19	INVESTIGATION SOURCE: Other
	COMPLIANCE DATE: 04/01/20

cc: Anthony J Tadsak , Dept of Safety & Professional Services