

WISCONSIN DEPARTMENT OF SAFETY AND PROFESSIONAL SERVICES



Wisconsin Department of Safety and Professional Services Access to the Public Records of the Reports of Decisions

This Reports of Decisions document was retrieved from the Wisconsin Department of Safety and Professional Services website. These records are open to public view under Wisconsin's Open Records law, sections 19.31-19.39 Wisconsin Statutes.

Please read this agreement prior to viewing the Decision:

- The Reports of Decisions is designed to contain copies of all orders issued by credentialing authorities within the Department of Safety and Professional Services from November, 1998 to the present. In addition, many but not all orders for the time period between 1977 and November, 1998 are posted. Not all orders issued by a credentialing authority constitute a formal disciplinary action.
- Reports of Decisions contains information as it exists at a specific point in time in the Department of Safety and Professional Services data base. Because this data base changes constantly, the Department is not responsible for subsequent entries that update, correct or delete data. The Department is not responsible for notifying prior requesters of updates, modifications, corrections or deletions. All users have the responsibility to determine whether information obtained from this site is still accurate, current and complete.
- There may be discrepancies between the online copies and the original document. Original documents should be consulted as the definitive representation of the order's content. Copies of original orders may be obtained by mailing requests to the Department of Safety and Professional Services, PO Box 8935, Madison, WI 53708-8935. The Department charges copying fees. *All requests must cite the case number, the date of the order, and respondent's name* as it appears on the order.
- Reported decisions may have an appeal pending, and discipline may be stayed during the appeal. Information about the current status of a credential issued by the Department of Safety and Professional Services is shown on the Department's Web Site under "License Lookup."

The status of an appeal may be found on court access websites at:

<http://ccap.courts.state.wi.us/InternetCourtAccess> and <http://www.courts.state.wi.us/wscga>

- Records not open to public inspection by statute are not contained on this website.

By viewing this document, you have read the above and agree to the use of the Reports of Decisions subject to the above terms, and that you understand the limitations of this on-line database.

Correcting information on the DSPS website: An individual who believes that information on the website is inaccurate may contact DSPS@wisconsin.gov

DIVISION OF INDUSTRY SERVICES

4822 MADISON YARDS WAY

MADISON WI 53705

Contact Through Relay

<http://dsps.wi.gov/programs/industry-services>

www.wisconsin.gov

Tony Evers, Governor

Dan Hereth, Secretary



NOTICE OF VIOLATIONS AND ORDERS

February 6, 2024

ORDER 0008964

EMRICK LLC

PO BOX 6

LAKE DELTON WI 53940

Site: Emrick Lake Campgrounds

3076 1ST COURT

TOWN OF JACKSON; ADAMS COUNTY

PARCEL: 012000190000

Regulated Objects:

Nature of Complaint Summary: Emrick Lake Campgrounds Cleanout Violations (24 COM 009)

Powers of the Department. Pursuant to Wis. Stat. § 145.02 the Department of Safety and Professional Services shall have general supervision of all construction, installation, and maintenance of plumbing in connection with all buildings in this state. The Department shall promulgate rules that shall uniformly apply to all types of buildings, private or public, rural or urban.

INVESTIGATION NOTES: Plumbing plans were submitted to the Department for review on or about February 9, 2023 (DIS-022306428). Those plans were denied by the Department on March 30, 2023. New plans were submitted by General Engineering on May 2, 2023 (DIS-052320552).

On May 16, 2023, the Department inspected the site. The Department noted that plumbing work had already been installed, prior to any plan approval. The Department learned that 23 new Private Onsite Waste Treatment Systems (POWTS) were installed. It was discovered that the hose bibbs for the backflow preventer were incorrectly installed. The breakoff screw was not set. The Department also noted that on one POWTS a vent cap was too low to the grade.

On June 7, 2023, the Department reviewed Plans DIS-052320552 and sent a letter to General Engineering requesting additional information. On July 10, 2023, the Department approved the plans.

On December 19, 2023, the Department visited the site for an inspection. The Department issued a progress report indicating that the inspection was not approved and that there were still outstanding violations at the site.

As of this writing the violations have still not been abated.

The following violations were revealed and shall be corrected pursuant to this Order:

1. **Violation:** On Approved Plans DIS 052-2320552 Page C2.1, attached, the clean-outs are not installed on site. Cleanouts are required per Wis. Admin. Code § SPS 382.30-382.37.

Wis. Admin. Code SPS § 382.10(1)(d) Basic Plumbing Principles: Drain systems shall be designed, constructed and maintained so as to conduct the wastewater or sewage efficiently and shall have adequate cleanouts. See *Wis. Admin. Code § SPS 382.30-382.37 for specific requirements.*


You are hereby ordered to have the violations corrected to conform to the indicated provisions of the Wisconsin Administrative Code and/or Wisconsin Statutes. These corrections shall be made no later than the compliance date noted, and upon correction of violations **please notify James Eddy at 608-789-7891 or james.eddy@wisconsin.gov.**

If you have any questions regarding this matter, please feel free to contact me at the number listed below or James Eddy.

Wis. Admin. Code § SPS 303.03 Permits any person affected by a rule of the department to petition for a variance of the rule. The petition needs to establish equivalency to the rule, be provided on the form from the department and be submitted with accompanying fee and municipal recommendation.


The Department may exercise such powers as are reasonably necessary to carry out the provisions of Wisconsin Chapter 145. It may issue special orders directing and requiring compliance with the rules and standards of the Department promulgated under this chapter whenever, in the judgment of the Department, the rules or standards are threatened with violation, are being violated or have been violated. The circuit court for any county where violation of such an order occurs has jurisdiction to enforce and shall enforce any order brought before it by injunctive and other appropriate relief. The attorney general or the district attorney of the county where the violation of the order occurs shall bring action for its enforcement. The department may issue an order under this paragraph to abate a violation of s. 254.59. See Wis. Stat. § 145.02(3)(f)

Wis. Stat. § 101.02(6) Any employer or other person interested either because of ownership in or occupation of any property affected by any such order, or otherwise, may petition for a hearing on the reasonableness of any order of the department in the manner provided in this subchapter. All requests must be received within 30 days of the date of this Order and shall set out specifically and in full detail the order upon which a hearing is desired and every reason why such order is unreasonable, and every issue to be considered by the department on the hearing. The petitioner shall be deemed to have finally waived all objections to any irregularities and illegalities in the order upon which a hearing is sought other than those set forth in the petition.

ATTORNEY NAME: Matthew McCasland		
PHONE/WORK HOURS: (608) 266-9814		
E-MAIL: matthew.mccasland@wisconsin.gov		INVESTIGATION TYPE: Requested
SIGNATURE:	DATE:	INVESTIGATION SOURCE: Other
	February 6, 2024	COMPLIANCE DATE: 4/1/2024

cc: Mike McNally

James Eddy



- NOTES:
1. PER DPS CODE CHAPTER 302.35, PRIVATE INTERCEPTOR MAIN SEWERS & OR LESS IN DIAMETER SHALL BE PROVIDED WITH AN EXTERIOR CLEANOUT OR MANHOLE UPSTREAM OF THE POINT OF THE CONNECTION OF THE PRIVATE INTERCEPTOR MAIN TO THE DERRICK LAKE. CLEANOUTS ARE LOCATED NOT MORE THAN 100 FEET AWAY.
 2. EXACT CLEANOUT LOCATIONS SHOULD BE VERIFIED DURING CONSTRUCTION.

0 250
Scale

W
N
S
E

DRAWN BY: JEA
REVIEWED BY: LAL
DATE: 6-29-2023
SHEET NO.: 26 OF 26
C2.1

REVISIONS	NO.	BY	DATE

SANITARY DRAINAGE SYSTEM
EMRICK LAKE CAMPGROUNDS
BUD DAGGETT

TOWN OF OXFORD
 ADAMS & MARQUETTE COUNTY, WI

General Engineering Company

P.O. Box 340 • 810 Silver Lake Dr. • Portage, WI 53257
 800-743-2100 (Office) • 608-743-2562 (Fax)
 www.geconline.com

This document contains confidential or proprietary information of General Engineering Company. It is to be used only for the project for which it was prepared. It is not to be reproduced, copied, or distributed without the written consent of General Engineering Company.

